ALCAD VTX 1 L 375 - Cell data sheet

Classification

| Brand | Alcad |
|--------------------------|-------------|
| Cell type | VTX 1 L 375 |
| Cell P/N | 31-05581-8* |
| Capacity at 5 hours rate | 375 Ah |
| IEC Designation | KGL375P |
| According to IEC 62259 | |



Physical data

| Overall height Width | 421 mm 195 mm | Weight per cell | 16,8 Kg |
|-------------------------|------------------|-------------------------|---------|
| Length | | Block length - 2 cells | 252 mm |
| Block length - 3 cells | 372 mm | Block length - 4 cells | |
| Block length - 5 cells | | Block length - 6 cells | |
| Block length - 7 cells | | Block length - 8 cells | |
| Block length - 9 cells | | Block length - 10 cells | |

Construction

Container material Separator type Connection torque Terminal size Polypropylene Felt 30,0 +/- 3,0 Nm M10 No. of terminals/polarity Terminal material Vent type

2 Steel low pressure flame arresting vent

Plates

Positive Type of plates

Maintenance Free Pocket Negative Type of plates

Maintenance Free Pocket

ALCAD confidential and proprietary. The data herein given are for information purposes only and are not binding on ALCAD. They may be modified without prior notice. Please contact an ALCAD representative in order to obtain confirmation of the above data. Visit our website at www.alcad.com

Version: 1.4, Last updated on 01/2015

ALCAD VTX 1 L 375 - Cell data sheet

Electrolyte

| Electrolyte type: Renewal Electrolyte type: Initial Electrolyte per cell: Liquid | E13 E22 4,0 liters | Max/Min Vent oil quantity | 50 mm | | |
|--|----------------------------|------------------------------|-------------|--|--|
| Connection | | | | | |
| Cable area | 120 mm² | | | | |
| Charging | | | | | |
| Float voltage Single-level voltage | 1,42 V/Cell 1,42 V/Cell | High rate voltage (min) | 1,45 V/Cell | | |
| Resistance/Short circuit | | | | | |
| Internal resistance | 0,65 mOhm | Short circuit current | 2094 A | | |

ALCAD confidential and proprietary. The data herein given are for information purposes only and are not binding on ALCAD. They may be modified without prior notice. Please contact an ALCAD representative in order to obtain confirmation of the above data. Visit our website at www.alcad.com